

Dfl Rivers Lisburn



Department for

Infrastructure

An Roinn

Bonneagair

www.infrastructure-ni.gov.uk

[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]

Ravarnet House
36 Altona Road
Lisburn, BT27 5QB
Tel: 028 92 606 100

Your ref:
Our ref: IN1-20-5882

Date: 04th June 2020

Dear [REDACTED]

RE: SCH6 Consent to Discharge - [REDACTED]

Thank you for your application received 09th April 2020 regarding Schedule 6 approval. From a drainage aspect my comments are as follows.

Dfl Rivers consents to storm discharge at your total stated maximum Greenfield rate of 16.8l/s to the watercourse shown on the submitted application. This watercourse is undesignated under the terms of the Drainage (Northern Ireland) Order 1973.

The Department accepts the outfall detail received with your application, and advises that it should be constructed in appropriate scale to the size of the outlet pipe. The discharge pipes and outlet structures should be turned in the direction of flow and anti-scour measures taken to prevent bank and bed erosion.

Attenuation method is to be by using a hydrobrake fitted manhole and appropriate storage systems within the site.

You should note that, in accordance with Paragraph 11 of Schedule 6 of the Drainage (Northern Ireland) Order 1973, any consents/ approvals given by Dfl Rivers under Schedule 6 shall not affect the liability of any riparian/developer to comply with other legislation. It is your responsibility to contact any other parties which may have an interest in your proposals e.g. NIEA, Landowners, Fisheries etc.

You are requested to notify Dfl Rivers of the commencement date of your works so that an inspection may take place during construction.

In giving its consent the Department would stress that it is your responsibility to ensure that the proposed works do not result in any obstruction to flow arising from blockage, structural failure, poor workmanship or any other reasons.

Please note that the responsibility for the continued maintenance of undesignated watercourses rest with riparian landowners.

This consent is valid for a period of 12 months from the date of this letter. If proposals are not completed within this period of time they should be resubmitted for further appraisal.

Please quote the above reference number in any future correspondence.

Yours sincerely

A solid black rectangular box used to redact the signature of Jonathan Steenson.

Jonathan Steenson
Engineering Section

Dfl Rivers Lisburn



Department for

Infrastructure

An Roinn

Bonneagair

www.infrastructure-ni.gov.uk

[REDACTED]

Ravarnet House
36 Altona Road
Lisburn, BT27 5QB
Tel: 028 92 606 100

Your ref:
Our ref: IN1-20-5882

Date: 24 June 2022

Dear Sir,

RE: Schedule 6 Discharge Consent renewal

Thank you for your application received 25 March 2022 regarding renewal of Schedule 6 approval. From a drainage aspect my comments are as follows.

Dfl Rivers is satisfied with your proposals to discharge at the total stated maximum rate of 16.8l/s to the watercourse as shown with the submitted application. This watercourse is undesignated under the terms of the Drainage (Northern Ireland) Order 1973.

Attenuation method is to be by using a hydrobrake fitted manhole and appropriate storage systems within the site.

The Department accepts the outfall detail submitted with your application and advises that it should be constructed in appropriate scale to the size of the outlet pipe. The discharge pipes and outlet structures should be turned in the direction of flow and anti-scour measures taken to prevent bank and bed erosion.

You should note that, in accordance with Paragraph 11 of Schedule 6 of the Drainage (Northern Ireland) Order 1973, any consents/ approvals given by Dfl Rivers under Schedule 6 shall not affect the liability of any riparian/developer to comply with other legislation. It is your responsibility to contact any other parties which may have an interest in your proposals e.g. NIEA, Landowners, Fisheries etc.

You are requested to notify Dfl Rivers of the commencement date of your works so that an inspection may take place during construction.

The Department would stress that it is your responsibility to ensure that the proposed works do not result in any obstruction to flow arising from blockage, structural failure, poor workmanship or any other reasons.

This is valid for a period of 24 months from the date of this letter. If proposals are not completed within this period of time they should be resubmitted for further appraisal.

Please quote the reference number at the top of this letter in any future correspondence.

Yours sincerely

A solid black rectangular box redacting the signature of Jonathan Steenson.

Jonathan Steenson
Engineering Section